

BPIR Declaration

Designated building product: Class 2

Ventüer has provided this declaration to satisfy the provisions of Schedule 1(d) of the Building (Building Product Information Requirements) Regulations 2022.

Product System

Name Ventüer AL-300W Acoustic Louvre
Line AL
Identifier 300W

Description

At 300mm deep, the Ventüer AL-300 louvre system is a mid-range acoustic attenuator suitable for use in situations where medium levels of noise reduction are required. Constructed with an extruded aluminium front blade profile, it offers a higher level of weather resistance than conventional acoustic louvres made from sheetmetal. The rear of the louvre can be fitted with bird mesh, insect mesh or dust filters. Available in a wide range of standard powdercoat colours, the AL-300W is manufactured to order and can be fabricated in a wide range of sizes. Independently tested and certified to ISO 10140-2.

Scope of Use

This 300mm deep louvre system, provides medium level of noise reduction. Compatible with all common structure and cladding types, including precast concrete, metal cladding, fibre cement sheet and unitised curtainwall systems. Aluminium construction, available in any standard powdercoat colour or anodising. The AL-300W can be fitted with ancillaries such as bird mesh, insect mesh, dust filters, mechanical dampers and plenums.

Relevant Building Code Clauses

Clause B1 Structure: Performance B1.3.3(a), B1.3.3(f), B1.3.3(h)

Clause E2 External moisture: Performance E2.3.2

Clause G4 Ventilation: Performance G4.3.1

Contributions to Compliance

- When sized correctly, the AL-300W louvre system complies with the requirements for natural ventilation of buildings under the New Zealand Building Code clause G4
- When installed in accordance with Ventüer technical literature, shop drawings and site-specific engineering the AL-300W louvre system complies with the requirements for structure under the New Zealand Building Code clause B1
- When installed in accordance with Ventüer technical literature and shop drawings the AL-300W louvre system complies with the requirements around external moisture as outline in New Zealand Building Code clause E2

Design Requirements

- 300mm deep, providing medium level of noise reduction
- Compatible with all common structure and cladding types, including precast concrete, metal cladding, fibre cement sheet and unitised curtainwall systems
- Aluminium construction, available in any standard powdercoat colour or anodising
- Can be fitted with ancillaries such as bird mesh, insect mesh, dust filters, mechanical dampers and plenums
- Independently tested and certified to ISO 10140-2
- Water ingress from wind driven rain can be substantial if exposed to high winds or situated where cross flow can occur [i.e. having louvres on both sides of an empty building such as a storage facility]
- If interior linings or equipment within the building can be damaged by exposure to water, consider using a multi-stage ventilation louvre such as the Ventüer VL-3SD or VL-2SD louvre system instead – Note – these alternative louvres do not have acoustic properties

Installation Requirements

Installation requirements for the AL-300W louvre system vary dependent on the site wind loads, louvre panel sizes, cladding type and primary structure detailing. Ventüer provides full shop drawings for all installations which show sequencing, fixing type and sizing, flashing requirements and sealant details. Installers should make themselves fully conversant with these shop drawings prior to installation commencing.

Supporting Evidence

The product has and can make available the following additional evidence to support the above statements: Contact Ventüer for further details.

Contact Details

| | |
|---|---|
| Legal & Trading Name of Manufacturer | Ventuer Limited |
| Address for Service | 76 Clayden Road, Warkworth, Auckland 0985 |
| Website | ventuer.co |
| Email | sales@ventuer.co |
| Phone | +64 09 9733616 |
| Manufacturer NZBN | 9429047214217 |